

| TEST RESULTS: | | | | | | |
|--------------------------------------|---------------|-----------------------------------|---|------|-----|---|
| Contaminant | Violation Y/N | Level Detected/Range of Detection | Unit Meas. | MCLG | MCL | Likely Source of Contamination |
| Microbiological Contaminants | | | | | | |
| Total Coliform Bacteria | N |) All clean for past 12 months | | | | |
| Fecal coliform and <i>E.coli</i> | N |) | | | | |
| Inorganic Contaminants | | | | | | |
| Lead & Copper | | | 10 Sample Sites - all within state limits | | | |
| Nitrate (as Nitrogen) | | | Mg/L | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks sewage erosion of natural deposits |
| Well #2 | N | 0.9 | | | | |
| Well #1 | N | 2 | | | | |
| Volatile Organic Contaminants | | | | | | |
| Well #1 & #2 | | No detection of any contaminants | | | | |

A complete listing of tested contaminants may be viewed in the Selectmen's Office or at EAI Labs

HEALTH EFFECTS INFORMATION

No contaminants exceeded the MCL. The following is provided for your information only:

Nitrate - Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.

Microbial Contaminants - Viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum productions, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.